

Serial No
JB34437



Registered Business/engineer details can be checked at www.gassaferegister.co.uk or by calling 0800 408 5500.

This form is not to be used as a Landlord's Gas Safety Record. Form GSR LGSR PAD2 can be used for this purpose.

GAS INSPECTION RECORD

Gas safe is a registered trade mark of HSE and is used under licence.



Details of Registered Business

Gas Safe Register No 572122

Registered Engineer's Name STEVE COLLIER

Gas Safe Register Licence Number 5573606

Business CAMPERTEC

Address UNIT 2 STATION ROAD
SHEPTON MALLETT, SOMERSET

Postcode BA4 5DD

Contact No 01749 340824

Details of Site Greenway Campground 3P2VXC

Name (Mr/Ms/Ms/Ms/Ms) W. TUES

Address 145 THE WARRENS
BOBE REGIS
WARHAM

Postcode BH20 7LT

Contact No 01712 832833

Rented accommodation state Yes or No:

NO

Gas User Signature:

Print name: WILL TUES Date: 29-1-2024

Gas Safe Engineer Signature:

Print name: S. COLLIER Date: 29/1/24

Gas Installation Inspection please tick box where appropriate

Outcome of gas tightness test? PASS/FAIL Further Information

Has the installation been installed using the correct materials? YES/NO

Is the installation pipework correctly sized? YES/NO

Is the Protective Equipotential bonding satisfactory? YES/NO

Emergency Control Valve(s)

Accessible and correctly positioned? YES/NO FURTHER INFORMATION

Correctly labelled? YES/NO

| Details of Appliance | Appliance 1 | Appliance 2 | Appliance 3 | Appliance 4 |
|---|---|---|---|--|
| Type | HOB | OVEN + GRILL | Room 4 WATER HEATER | |
| Manufacturer | THERMO | THERMO | TRUMA | |
| Model | S345 | DUPLEX | COMBI 2E | |
| Type of flue OF/RS/FL | FL | FL | RS | |
| Chimney condition & termination satisfactory? | Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A <input checked="" type="checkbox"/> | Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A <input checked="" type="checkbox"/> | Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> N/A <input type="checkbox"/> | Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A <input type="checkbox"/> |
| Flue operation checks | Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A <input checked="" type="checkbox"/> | Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A <input checked="" type="checkbox"/> | Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> N/A <input type="checkbox"/> | Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A <input type="checkbox"/> |
| Ventilation satisfactory? | Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> N/A <input type="checkbox"/> | Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> N/A <input type="checkbox"/> | Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> N/A <input type="checkbox"/> | Pass <input type="checkbox"/> Fail <input type="checkbox"/> N/A <input type="checkbox"/> |
| Operating pressure in mbars and/or heat input kW/h or Btu/h | 30mbars | 30mbars | 30mbars | |
| Combustion analyser reading (if applicable) | | | | |
| SAFE TO USE | Yes <input type="checkbox"/> No <input type="checkbox"/> | Yes <input type="checkbox"/> No <input type="checkbox"/> | Yes <input type="checkbox"/> No <input type="checkbox"/> | Yes <input type="checkbox"/> No <input type="checkbox"/> |

Overall Risk Assessment

Are the gas installation/appliances inspected safe for use? YES/NO

If No, issue a Warning/Advice Record (insert serial No.) Have warning labels been affixed? YES/NO

Brief description of any further work required

NIL.